

R&D Building services – Jan2026

Bridgestone EMEA Tech Center  
Energy & Environment Management System  
ISO50001

**BRIDGESTONE**  
*Solutions for your journey*

Gianluca Staiano

# Agenda

- Bridgestone EMEA Technical center
- Monitoring
- Energy Efficiency - main projects
- Future - New Buildings

# Bridgestone EMEA Tech Center

Bridgestone EMEA Technical center has been ISO 50001 and 14001 certified since 2011.

Main activities:

- Tire design
- Tire manufacturing
- Indoor Testing
- Outdoor testing
- Chemical and physical laboratory testing





# Bridgestone EMEA Tech Center

- 2 Natural gas Steam generators
- 3 Natural gas Pressure reducing cabins
- 4 Electric steam generators
- 3 hot water production Boilers
- 21 Chiller
- 10 Hydraulic substations with 180 pumps
- 4 compressed air stations
- 3 vacuum stations
- 2 Osmotic Water Plant
- 2 Softned Water Plant
- 42 Industrial air conditioner
- 40 air Extractors
- 26 AHU Civil Air Conditioning
- 34 AHU Industrial Air Conditioning (test indoor)
- 13 Evaporative Towers
- 7 Dust Collector
- 178 Fancoil
- 1 Wastewater treatment plant





# Monitoring – Energy Main Offenders

Energy Sentinel System by Energy Team:


156 electric meters installed in TCE, EUPG and EEC to monitoring 97% electric consumption.

21 water meters, 4 natural gas meters, 3 air compressed meters, 4 cooling energy meters and 3 steam meters installed in TCE.



## By Energy source

- 86% Electricity
- 11% Natural gas
- 2,6% Diesel/Gasoline
- 0,4% LPG






## By Department

- 28% Utilities
- 26% Testing
- 19% Tyre production
- 21% Common services
- 6% Laboratories

BRIDGESTONE EUROPE NV/SA Italian Branch	Sistema di Gestione Energia, Ambiente, Salute e sicurezza		ANALISI DI SIGNIFICATIVITA' DEGLI ASPETTI ENERGETICI		Registro
Aspetto energetico	incidenza sui consumi	margini di	significatività	KPI	EHS 1500 R-01 monitoraggio
Consumi di energia elettrica per la produzione di miscela	7,6% delle emissioni di CO2 - elevata	Possibilità di ridurre il consumo del 10% in 5 anni - bassa	Media	kWh/kg CPD	mensile
Consumi di energia elettrica per la produzione di pneumatici e sealant	7,9% delle emissioni di CO2 - elevata	Possibilità di ridurre il consumo del 10% in 5 anni - bassa	Media	kWh/GT	mensile
Consumi di energia elettrica per il testing degli pneumatici sperimentali	17,5 % delle emissioni di CO2 - elevata	Possibilità di ridurre il consumo del 10% in 5 anni - elevato	Elevata	kWh/km	mensile
Consumi di energia elettrica per la produzione di aria compressa	3,7% delle emissioni di CO2 - media	Possibilità di ridurre il consumo del 10% in 5 anni - media	Media	kWh/mc aria	mensile
Consumi di energia elettrica per la produzione di acqua refrigerata	8,1% delle emissioni di CO2 - elevata	Possibilità di ridurre il consumo del 10% in 5 anni - bassa	Media	kWhe/HWhf	mensile
Consumi di energia elettrica per la gestione delle sotto centrali	8,6 % delle emissioni di CO2 - elevata	Possibilità di ridurre il consumo del 10% in 5 anni - bassa	Media	kwh	mensile









# Electricity - Departments details



## Main EnPI:



- Tyre production
- Indoor Testing
- Laboratories
- Utilities



# Energy Efficiency main projects - Steam trap



Steam trap:

- Replacement stem trap following thermographic and ultrasonic investigation
- .Reduction of 25% of natural gas consumed for steam production




# Energy Efficiency main projects - Idraulic substations

Pompe refrigerata Building B/NA



**ANNUAL: SAVING 210 MWh**




Pompe refrigerata building NH/NH2



# Energy Efficiency main projects - Lights

Since 2012, 80% of neon lamps have been replaced with LEDs.

Electricity for lighting has been reduced by 37%





# Energy Efficiency main projects - Air compressors

Compressed air production:


- ON/OFF Compressors replaced with 2 inverter compressors size 110 kW.
- Electricity for air compressed production has been reduced by 30%



Monitoring compressed air leaks with ultrasound and repairs during shutdown





# Water consumption – ISO 14001



- 14% reduction in softened water consumption 2024 vs 2023 (41830 vs 48930 mc)
- 11% reduction in well water consumption 2024 vs 2023 (54210 vs 61000 mc)  
SAVING 13890 mc of water, equivalent to 6 Olympic swimming pools



# Energy Efficiency - New Buildings



- From 2024 to 2026, 6 new buildings, Steam plant, Compressed air station.
- These new buildings have installed high efficiency systems (LED lighting, PV systems 500 kW, High efficiency motors)
- Annual production of approximately 4.5% of TCE electric consumptions, from the photovoltaic systems serving new buildings



# Energy Efficiency - New Buildings

Hot water recovery system from the press department to preheat the water entering the boiler for the production of hot water for the operators' showers

SCHEMA FUNZIONALE

